

Skill Sheet 13-I-23

Objective 40: Extend a hoseline. (NFPA® 1001, 5.3.10)

Student Name: _____ **Date:** _____

Directions

For this skills evaluation checklist, students will extend a hoseline. Students should place a charged hand line 150-200 feet (46-61 m) on the ground. Have firefighters advance the line until it is completely stretched to its limits.

Equipment & Materials

- Full protective clothing including SCBA
- Charged hand line (1½- to 3-inch [38 to 77 mm]) with nozzle
- Hose clamp

Criteria & Evaluation Comments

Criteria (determined by the AHJ)

After the candidate has completed the skill sheet, write comments below.

Evaluator/Candidate Comments

Pass

☐

Fail

☐

Evaluator Signature

Date

Student Signature

Date

Skills Evaluation Checklist

Objective 40: Extend a hoseline.

Task Steps		Yes	No
1.	Bring additional sections of hose as needed to the nozzle end of the hoseline.		
2.	Open the nozzle slightly.		
3.	Apply a hose clamp approximately 5 feet (1.5 m) behind the nozzle OR call for hoseline to be shut down at the pump panel.		
4.	Remove the nozzle.		
5.	Add the new section(s) of hose.		
6.	Reattach the nozzle.		
7.	Recharge the hoseline by slowly releasing the hose clamp or calling for the line to be charged.		
8.	Check nozzle pattern and bleed air from hoseline.		